

Certificate of **Continued Compliance** 222350059/AA/00



15-12-2022

Replaces

Expiry date

15-12-2026

Page

1/4



In compliance with the procedure specified in the Alarm Components Scheme, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:

Trademark:

Type designation: Hardware / Software: Intrusion detector

OPTEX FLX-P-ST 1 / 1086.1

Placed on the market under the name or trademark of:

Name of the manufacturer:

Address:

City: Country: Optex Co., LTD. Ogoto Shiga 5-8-12 520-0101 Otsu City

JΡ

This certificate is granted to:

Name of the certificate holder:

Address: City:

Country:

Optex Co., LTD. Ogoto Shiga 5-8-12

520-0101 Otsu City

JΡ

Telefication B.V. Kiwa FSS Products

Wilmersdorf 50 Postbus 137 7300 AC Apeldoorn The Netherlands

https://www.kiwa.com/nl/en /specials/fire-safety-and-security

Ron Scheepers Managing director

This certificate has THREE Annexes.



Remarks and observations

The following conditions are applicable:

Security grade: 2 Environmental class: II Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2. This equipment can be used in combination with bracket CW-G2.

Factory location:
OPTEX(DONGGUAN) CO.,LTD.
No.2, Jufu Road, Banhu, Huanginang Town,
GuangDong, 523752,
DongGuan City,
P.R.China

Product inspection location: Nippon Express Nederland Industrieweg15 Voorschoten The Netherlands

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: P000237914-001-Ver. 1.00, 25 November 2022
- Telefication B.V.: P000117699-001-Ver.2.00, 25 July 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2 December, 2021

Applied Standards

EN 50130-5 June, 2011 EN 50130-4+A1 October, 2014 EN 50131-1+A1+A2+A3 June, 2020

The product as described in this certificate includes the following type designations

- Product description: Intrusion detector

- Trademark: OPTEX- Type designation: FLX-P-ST

- Hardware version: 1

- Software version: 1086.1